

niv+comp

OPERATING INSTRUCTIONS FOR MODELS H 25-PROBAG / R 25-ALCASE



FAST AND PRECISE ONE-MAN LEVELLING!

Measure levelness, gradients, pivot points, do levelling on opposite walls, between trenches and crossbeams as well as over obstacles, even to points that are not in direct view.

CONTENTS

- | | |
|---|-------------------------------------|
| 1. Parts and descriptions | 9. Settings and special displays |
| 2. Function and applications | 10. Replacing battery |
| 3. Working area | 11. Care and maintenance tips |
| 4. Display when operating | 12. Accessories (optional) |
| 5. Levelling | 13. Attention: operational safety ⚠ |
| 6. Instructions for taking exact measurements | 14. Malfunctions |
| 7. Motion filter | 15. Technical data |
| 8. Function check | 16. Guarantee & service |

1

PARTS AND DESCRIPTIONS

niv±comp



2

FUNCTION AND APPLICATIONS

niv±comp


The **niv±comp** device consists of a hose drum with pull-out winder handles, a special hose and handset. There is a liquid reservoir with a pressure screw in the centre of the drum. A high-quality measuring device in the handset determines the pressure difference resulting from the difference in height between the handset and liquid reservoir.

The main applications for **niv±comp** are levelling and taking measurements to check dimensions in interior construction. Particular attention must be paid to the instructions on taking exact measurements when using the device outside (Section 6).

3

WORKING AREA

niv±comp



The device can be used to check the gradient of sloping surfaces as well as being used in horizontal and vertical positions.



Press button to switch device on



Reference level not yet stable



Reference level is stable, press button to save reference level (Display [-ni])



Level = reference level. Values such as ± 12 or $+ 503$ show deviation from reference level in millimetres or inches.

Saving new reference level:

Press button until display shows ----. Then save reference level again (see above).



The device can be switched off by holding the button down or is switched off automatically 33 minutes after the button was last pressed.

Flashing LED for use in dark:

Zero level: LED flashes evenly

Too low: LED flashes slowly

Too high: LED flashes quickly

- Place the case or hose drum in a stable position. The hose drum must not be moved whilst it is being used for levelling (!).
- Turn the pressure screw (S) as far as it will go in the direction marked "Measure" (indicator peg is down).
- Remove handset and roll out a sufficient amount of hose.
- Check that hose temperature is the same as that of the surroundings (Section 6).
- Switch handset on using button (T) and place at reference level (this exact position must be used for measurement), alignment of device by eye is sufficient.
- Make sure that the hose is not moving; wait until display is stable, press button quickly when display has shown stable value ...0 for about 3 seconds. (Display [-ni], then relative height measurement).
- Take the handset to the desired position, correct the vertical position until the display shows a stable value of ...0 (levelling) or until the measured value (control measurement) is reached. The height can now be marked or read (same procedure for other points to be measured).

To save new reference level:


Press button until display shows ---- again.

To end measurement:

Put handset down (or back in case), roll the hose up making sure it is clean and not twisted. The pressure screw (S) should be turned as far as possible in the direction marked "Store" (indicator peg is up) when the device is being stored.

PLEASE NOTE:

The levelling device and interior of the case should be kept dry at all times.



- It is useful to use some kind of position marker (nail) if one particular reference level is required often.
- The device should be opened and the hose unwound and left for a few minutes to reach the right temperature if the temperature has changed significantly (e.g. after transporting the device in a vehicle that was very warm or cold).
- Place the handset exactly on the measurement points and do not change the marking or visual angles. Deviation from zero level is shown from +/- 0.2 mm.
- Do not throw the hose (pressure waves)! Avoid touching the hose with warm hands when it is cold.

The following applies to taking measurements outdoors:

Climatic influences in the open can lead to increased deviation. Keep the device and its components out of intensive or changeable levels of sunlight and do not run the hose over warm surfaces or in areas where temperature is variable (e.g. in currents of air at building facades).

The best results can be achieved in the open at times where climatic conditions are favourable (at daybreak). The measurement points should then be worked through without interruption where possible.

A motion filter can be activated by pressing the button twice when the device is in levelling mode. The  symbol appears briefly. It can sometimes be an advantage if the reading does not react immediately to interfering vibration of the floor or hose. The filter can be deactivated by one short press of the button.

(See also the section “Malfunctions”)

The following control values can give a rough idea of how niv±comp functions as a measurement device:

- **A) Stability of measured values (at same temperature):**
Place the handset in a horizontal position and record the level once you are sure the reading is stable. The displayed value may only change by a maximum of 1 millimetre if the handset is left in position at this point or if it is returned within a period of a few minutes.
- **B) Pressurisation:**
Switch the handset on with the pressure screw in the “Measure” position then place it next to the hose drum and save the level measured.
Turn the pressure screw to its final position “Store”. The value displayed should lie within a range of 600...1800.

It is possible to make corrections to height calibration and to personalise the settings for the display of measured values using **niv±comp**. You can call the menu up by keeping the button pressed down when switching the device on until **SEtT** is displayed. Let the button go – the settings options will be displayed slowly in sequence. You can change the settings by pressing the button.

+h 0 Correct the height display by +1 mm per press of the button.

-h 0 Correct the height display by -1 mm per press of the button. Corrections are implemented if you do not press the button for 5 seconds. We recommend that you take an exact measurement of 1000 mm in height difference to ensure correct measurement.

+ or Select the deviation display by +/- or arrow.

inch or **mm** Select the height display in inches or millimetres.

r Return to factory settings (Reset).

SetUp is being saved (Animation)

Special displays:

Indication that battery should be replaced (from ~20% reserve)

bAtT Warning (flash) battery is empty (from ~10% reserve). The device switches itself off when the battery is exhausted.


Critical temperature change

Overranging of measured value

ANZEIGE PULSIERT for three minutes from 30 minutes after the button was last pressed. The device then switches itself off. A short press of the button extends the time.


REPLACING BATTERY

The battery must be replaced when **bAtT** is displayed. Undo the screws in the upper cover of the handset and tighten them lightly after replacing the battery. Use AA (LR6) alkaline batteries.



Always store **niv±comp** in a dry place and keep it clean to make sure it stays in good condition for a long time. Wax-free and solvent-free cleaning products only may be used (washing liquid). The device is best protected from damage when always packed away after use.

If the device is to be stored for a longer period of time, ensure that it is dry and that the pressure screw is in the “Store” position.



ACCESSORIES (OPTIONAL)

The accessory package contains a holder, a tracer arm set, a magnetic holder (max. 10 kg) and a protective knob.

The accessory package makes it possible to increase the vertical area where measurements can be made (see also fig. Working area). The tracer arms are placed at the top or bottom of the holder depending on the direction to be measured in and the protective knob or magnet is placed on the end of the arm.



ATTENTION: OPERATIONAL SAFETY!

- Do not run the hose higher than floor level (Danger: it could be a mantrap or get caught up in a vehicle).
- The protective knob should always be used when using the extension for the tracer arm from the accessory package!
- Do not use the magnetic holder above head height!

MALFUNCTIONS

General functions:

The device will not switch on or switches off randomly: check battery, check battery contacts. Battery symbol flashes and device switches off: replace battery.

Errors in levelling:

Have you checked the pressure screw and temperature moderation?
Have you followed the instructions on “Measurements outdoors“?
Is the case damp or has water got in?

Levelling errors resulting from bubbles in the hose or sensor connection:

(This is possible as a result of serious neglect of the pressure screw or following exposure to extreme heat or some other kind of shock) Leave the device in the storage position for a few days then check it again.

Failure as a result of damp:

Do not let the closed case get damp – dry the device – leave the case open. If water gets in to the handset, the battery must be removed immediately. The battery can only be put in again after all parts have been dried thoroughly.

■ Damage to the hose system:

The hose is thick and robust so slight damage to the outer skin is not critical. The hose and hose system can withstand great strain. However, repair will be required if there is a leak of fluid. Clean the fluid (non-toxic / neutral / oily) up using suitable means and dispose of in accordance with the regulations on waste oil.

15

TECHNICAL DATA

niv±comp

Principle of measurement.....	analogue with digital display
Reproducibility as typical value inside buildings	±2 mm
At a maximum distance of measurement point	48 m
Vertical working area	± 2,5 m (± 4,0 m)
Manual calibration of height display	(mm/Inch)
Operational temperature range approx	0...+35 °C
Battery-powered operation	1 x AA / LR6 (Alkaline) 1,5V
Power consumption / Operating time	~10 mW / 250 h
Automatic switch-off	after 33 mins. if button is not pressed
Low-level of emissions in accordance with EMC product standards.	
Shock resistance	impact from height of approx. 1 m
Storage and transport	-10...+40 °C (limited -30...+55 °C)
Dimensions	450 x 420 x 150 mm ³
Weight	approx. 5,5 kg
Regulations for recycling of electronic scrap, plastics and waste oil apply.	

16

GUARANTEE & SERVICE

niv±comp

Sales and service are available through reputable specialised dealers.

Repairs made during the guarantee period are free of charge, provided it can be proved that the fault resulted from a material defect or defect in manufacture.

When a claim is made under guarantee, the device should **cleaned thoroughly, packed** and returned to the supplier.

The following should be enclosed with the package:

1. Proof of purchase or receipt showing date of purchase,
2. Description of defect.

